

The Clear Choice in Gully Protection

Flow Test Report



T: 01531 828960 E: info@forestgroupuk.co.uk
For more advice visit www.forestgroupuk.co.uk




The Gully Guard is an engineered and sustainable solution to protect drainage systems from build stage and operational waste materials, debris, silt and pollutants.





The experimental system (pictured) was established to replicate a full scale gully system with measuring and collection pipework connected to the gully pot outlet.

Two tests were conducted for each of eight different flow rates (with and without a Gully Guard installed). All tests were conducted under steady flow conditions and the relationship between flow depth and rate was calibrated to be equivalent to recognised storm return periods.




The Results

Table 1 & Figure 5*:

"Evaluation of changes in standard roadside gully pots during operation of Gully Guard product under simulated drainage conditions" Department of Civil and Structural Engineering, University of Sheffield July 2013.

Without Gully Guard installed						With Gully Guard installed		
Return period (years)	Rainfall intensity (mm/hr)	Flume inflow rate (I/s)	Depth of gully approach flow (mm)	Flow through gully pot (I/s)	Proportion of flow through gully pot (%)	Depth of gully approach flow (mm)	Flow through gully pot (Vs)	Proportion of flow through gully pot (%)
2	17.2	1.2	2.1	0.36	29.7	2	0.36	29.8
5	25.5	1.78	3	0.51	28.6	3.1	0.43	24
10	33.4	2.03	4	0.63	31.1	3.9	0.63	30.8
30	41.85	3.81	6.1	1.17	30.8	6	1.13	29.6
50	48.9	5.33	6.2	1.52	28.4	6.1	1.51	28.4
200	55.25	6.29	8.1	2.08	33.1	7.3	1.98	31.6
500	74.25	11.25	10.1	3.19	28.3	10.1	3.16	28.1
N/A	100.25	27.86	15	7.63	27.4	14.6	7.59	27.2

Table 1



Calculated design return period / Flow into flume (I/s)

Conclusion

The University of Sheffield concluded that there is no significant difference in the flow rate through a gully pot with or without a Gully Guard installed and hence an installed Gully Guard will not significantly affect surface water drainage or present a flood risk.

^{*}Table 1 and Figure 5 are results taken from The University of Sheffield report - Evaluation of flow changes in standard roadside gully pots during operation of the Gully Guard product under simulated drainage conditions, full report available upon request.